

Exiting local amendment

Delete Section 2306.2.3 Above Ground Storage tanks located outside, above grade

Above-ground storage tanks for flammable and combustible liquids not permitted within Village of Westmont.

Proposed revision

Delete Section 2306.2.3 Above Ground Storage tanks located outside, above grade **Add;**

Above-ground storage tanks for flammable and combustible liquids not permitted within Village of Westmont. **Except as noted;**

1. Above ground storage tanks may be APPROVED by Westmont Fire Department for emergency situations. All installations in this instance shall conform to all state and local codes.
2. Above ground storage tanks may be APPROVED by the Westmont Fire Department for storage of new and used cooking oil per the following specifications
 - a. AST must be APPROVED by the Illinois State Fire Marshall
 - b. AST shall not exceed 600 gallons in total volume.
 - c. Only Class IIIB flammables (cooking oils only) shall be stored in APPROVED tanks.
 - d. All installations shall conform with state and local codes